



## Bacteriological Analysis Results

Pueblo Department of Public Health and Environment Laboratory  
101 W. 9th Street  
Pueblo, CO 81003  
(719) 583-4318  
pueblohealth.org

If you have not pre-paid your sample(s) please consider this your INVOICE and results.

---

Navajo Western Water District  
705 Navajo Rd.  
Walsenburg CO 81089

**Sample:** 20-3643      **PWSID:** CO0128625      **System Name:** Navajo Western Water District  
**Collector:** Tom Northup      7/9/2020      8:01:00 AM      RTOR  
**Address:** 127 Badger Rd      Sample Tap      **County:** Huerfano  
**Chlorine Residual:** 0.51mg/L      Routine Distribution      **Fee for Sample:** \$21.00  
**Received By:** Ceasar      7/9/2020      9:30:00 AM  
**AnalysisMethod:** Colilert  
**Results:**      **Total Coliform:** Absent      **E.coli Result:** Absent  
   **Results Date:** 7/10/2020      10:45:00 AM      **Analyst:** Espeseth  
**Comments:**

---

Navajo Western Water District  
705 Navajo Rd.  
Walsenburg CO 81089

**Sample:** 20-3644      **PWSID:** CO0128600      **System Name:** Navajo Western Water District  
**Collector:** Tom Northup      7/9/2020      7:30:00 AM      RTOR  
**Address:** 3211 CR 510      Sample Tap      **County:** Huerfano  
**Chlorine Residual:** 0.43mg/L      Routine Distribution      **Fee for Sample:** \$21.00  
**Received By:** Ceasar      7/9/2020      9:30:00 AM  
**AnalysisMethod:** Colilert  
**Results:**      **Total Coliform:** Absent      **E.coli Result:** Absent  
   **Results Date:** 7/10/2020      10:45:00 AM      **Analyst:** Espeseth  
**Comments:**

---

Friday, July 10, 2020

Page 1 of 1

**Note: Compliance sample records are only maintained and available for five years (Reference 40 CFR 141.33). PDPHE laboratory includes chlorine residual data reported on the request for analysis form when sending results to Colorado Department of Public Health and Environment, Water Quality Control Division.**

**NOTICE: Effective 1-1-2020 fees for Colilert presence/absence testing will be \$21.00. Fees for Enumerated coliform and E. coli testing will be \$23.00.**