



Bacteriological Analysis Results

Pueblo Department of Public Health and Environment Laboratory
101 W. 9th Street
Pueblo, CO 81003
(719) 583-4318
pueblohealth.org

If you have not pre-paid your sample(s) please consider this your INVOICE and results.

Navajo Western Water District
705 Navajo Rd.
Walsenburg CO 81089

Sample: 21-3401 **PWSID:** CO0128600 **System Name:** Navajo Western Water District
Collector: Tom Northup 7/8/2021 7:50:00 AM RTOR
Address: 5037 Comanche Dr Sample Tap **County:** Huerfano
Chlorine Residual: 0.47mg/L Routine Distribution **Fee for Sample:** \$21.00
Received By: Aguilar 7/8/2021 9:23:00 AM
AnalysisMethod: Colilert
Results: **Total Coliform:** Absent **E.coli Result:** Absent
Results Date: 7/9/2021 10:15:00 AM **Analyst:** Ceasar
Comments:

705 Navajo Rd.
Walsenburg CO 81089

Sample: 21-3253 **PWSID:** CO0128625 **System Name:** Navajo Western Water District
Collector: Tom Northup 7/6/2021 8:10:00 AM RTOR
Address: 127 Badger Rd Sample Tap **County:** Huerfano
Chlorine Residual: 0.46mg/L Routine Distribution **Fee for Sample:** \$21.00
Received By: Aguilar 7/6/2021 9:41:00 AM
AnalysisMethod: Colilert
Results: **Total Coliform:** Absent **E.coli Result:** Absent
Results Date: 7/7/2021 10:00:00 AM **Analyst:** Aguilar
Comments: