



Bacteriological Analysis Results

Pueblo Department of Public Health and Environment Laboratory
101 W. 9th Street
Pueblo, CO 81003
(719) 583-4318
pueblohealth.org

If you have not pre-paid your sample(s) please consider this your INVOICE and results.

Navajo Western Water District
705 Navajo Rd.
Walsenburg CO 81089

Sample: 22-4723 **PWSID:** CO0128625 **System Name:** Navajo Western Water District
Collector: Tom Northup 9/6/2022 7:55:00 AM RTOR
Address: 62 Buffalo Dr N Sample Tap **County:** Huerfano
Chlorine Residual: 0.38mg/L Routine Distribution **Fee for Sample:** \$21.00
Received By: Ceasar 9/6/2022 9:15:00 AM
AnalysisMethod: Colilert
Results: **Total Coliform:** Absent **E.coli Result:** Absent
 Results Date: 9/7/2022 10:14:00 AM **Analyst:** Maez
Comments:



Bacteriological Analysis Results

Pueblo Department of Public Health and Environment Laboratory
101 W. 9th Street
Pueblo, CO 81003
(719) 583-4318
pueblohealth.org

If you have not pre-paid your sample(s) please consider this your INVOICE and results.

Navajo Western Water District
705 Navajo Rd.
Walsenburg CO 81089

Sample: 22-4722 **PWSID:** CO0128600 **System Name:** Navajo Western Water District
Collector: Tom Northup 9/6/2022 7:32:00 AM RTOR
Address: 3046 Comanche Dr Sample Tap **County:** Huerfano
Chlorine Residual: 0.49mg/L Routine Distribution **Fee for Sample:** \$21.00
Received By: Ceasar 9/6/2022 9:15:00 AM
AnalysisMethod: Colilert
Results: **Total Coliform:** Absent **E.coli Result:** Absent
 Results Date: 9/7/2022 10:14:00 AM **Analyst:** Maez
Comments: