



Colorado Department
of Public Health
and Environment

Total Trihalomethane Certified Laboratory Report Form
WQCD - Drinking Water CAS
Submit Online at <http://www.wqcdcompliance.com/login>

Revision: 4/13/2015

TTHM

Public Water System Information		Laboratory Information	
PWSID#: CO0128600	Facility ID:DS001	Laboratory ID: CO015	
System Name: Navajo Western Water District (Resorts)		Laboratory Name: Colorado Analytical Laboratory	
Contact Person: Julie Zahringer	Phone #: 719-589-1024	Contact Person: Customer Service	Phone: 303-659-2313
Comments:		Comments:	

Section III (Supplied or Completed by PWS)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Sample Pt ID On Schedule	Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
8/18/21	DBP001	Apache Drive	8/19/21	8/21/21	210819077-02A	Chloroform	EPA-524.2	N/A	0.5	BDL
						Bromoform	EPA-524.2	N/A	0.5	40.7
						Bromodichloromethane	EPA-524.2	N/A	0.5	1.9
						Dibromochloromethane	EPA-524.2	N/A	0.5	10.6
						Total Trihalomethanes	EPA-524.2	80	0.5	53.3

NT: Not Tested
Lab MRL: Laboratory Minimum Reporting Level
BDL: Below Laboratory MRL. A less than (<) may also used.

ug/L: Micrograms per Liter
MCL: Maximum Contaminant Level

8/30/21
210819077
1/1
Y



Colorado Department
of Public Health
and Environment

Haloacetic Acids Certified Laboratory Report Form
WQCD - Drinking Water CAS
Submit Online at <http://www.wqcdcompliance.com/login>

Revision: 4/13/2015

HAA5

Public Water System Information				Laboratory Information			
PWSID#: CO0128600		Facility ID: DS001		Laboratory ID: CO015			
System Name: Navajo Western Water District (Resorts)				Laboratory Name: Colorado Analytical Laboratory			
Contact Person: Julie Zahringer		Phone #: 719-589-1024		Contact Person: Customer Service		Phone: 303-659-2313	
Comments:				Comments:			

Section III (Supplied or Completed by PWS)			Section IV (Supplied or Completed by Certified Laboratory)							
Sample Date	Sample Pt ID On Schedule	Address - Location	Lab Receipt Date	Lab Analysis Date	Laboratory Sample ID #	Analyte	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
8/18/21	DBP001	Apache Drive	8/19/21	8/25/21	210819077-02	Monochloroacetic Acid	EPA 552.2	N/A	2.0	BDL
						Monobromoacetic Acid	EPA 552.2	N/A	1.0	1.1
						Dichloroacetic Acid	EPA 552.2	N/A	1.0	BDL
						Trichloroacetic Acid	EPA 552.2	N/A	1.0	BDL
						Dibromoacetic Acid	EPA 552.2	N/A	1.0	7.4
						Total Haloacetic Acids	EPA 552.2	60	1.0	8.5

NT: Not Tested
Lab MRL: Laboratory Minimum Reporting Level
BDL: Below Laboratory MRL. A less than (<) may also used.

ug/L: Micrograms per Liter
MCL: Maximum Contaminant Level

8/30/21
210819077
1/1
Y



Colorado Department
of Public Health
and Environment

Organic Chemicals Certified Laboratory Report Form
WQCD - Drinking Water CAS
Submit Online at <http://www.wqcdcompliance.com/login>

Revised 4/13/2015

VOC/SOC

Section I (Supplied or Completed by Public Water System)		Section II (Supplied or Completed by Certified Laboratory)	
Public Water System Information		Certified Laboratory Information	
PWSID#: CO0128600		Laboratory ID: CO015	
System Name: Navajo Western Water District (Resorts)		Laboratory Name: Colorado Analytical Laboratory	
Contact Person: Julie Zahringer	Phone #: 719-589-1024	Contact Person: Customer Service	Phone: 303-659-2313
Comments:	Do Samples Need to be Composited BY THE LAB? <input type="checkbox"/>	Comments:	

Section III (Supplied or Completed by Public Water System)	
PWSID#: CO0128600	Collector: Tom Northup
Sample Date: 8/18/21	Facility ID (On Schedule): 001
	Sample Pt ID (On Schedule): 001

Section IV Volatile Organic Chemicals (Supplied or Completed by Certified Laboratory)								
Lab Receipt Date	Lab Analysis Date	Lab Sample ID	Analyte Name	CAS No.	Analytical Method	MCL (ug/L)	Lab MRL (ug/L)	Result (ug/L)
8/19/21	8/25/21	210819077-01	1,1,1-Trichloroethane	71-55-6	EPA-524.2	200	0.5	BDL
8/19/21	8/25/21	210819077-01	1,1,2-Trichloroethane	79-00-5	EPA-524.2	5	0.5	BDL
8/19/21	8/25/21	210819077-01	1,1-Dichloroethylene	75-35-4	EPA-524.2	7	0.5	BDL
8/19/21	8/25/21	210819077-01	1,2,4-Trichlorobenzene	120-82-1	EPA-524.2	70	0.5	BDL
8/19/21	8/25/21	210819077-01	1,2-Dichloroethane	107-06-2	EPA-524.2	5	0.5	BDL
8/19/21	8/25/21	210819077-01	1,2-Dichloropropane	78-87-5	EPA-524.2	5	0.5	BDL
8/19/21	8/25/21	210819077-01	Benzene	71-43-2	EPA-524.2	5	0.5	BDL
8/19/21	8/25/21	210819077-01	Carbon Tetrachloride	56-23-5	EPA-524.2	5	0.5	BDL
8/19/21	8/25/21	210819077-01	Monochlorobenzene	108-90-7	EPA-524.2	100	0.5	BDL
8/19/21	8/25/21	210819077-01	cis-1,2-Dichloroethylene	156-59-2	EPA-524.2	70	0.5	BDL
8/19/21	8/25/21	210819077-01	Dichloromethane	75-09-2	EPA-524.2	5	0.5	BDL
8/19/21	8/25/21	210819077-01	Ethylbenzene	100-41-4	EPA-524.2	700	0.5	BDL
8/19/21	8/25/21	210819077-01	o-Dichlorobenzene	95-50-1	EPA-524.2	600	0.5	BDL
8/19/21	8/25/21	210819077-01	Para-Dichlorobenzene	106-46-7	EPA-524.2	75	0.5	BDL
8/19/21	8/25/21	210819077-01	Styrene	100-42-5	EPA-524.2	100	0.5	BDL
8/19/21	8/25/21	210819077-01	Tetrachloroethylene	127-18-4	EPA-524.2	5	0.5	BDL
8/19/21	8/25/21	210819077-01	Toluene	108-88-3	EPA-524.2	1000	0.5	BDL
8/19/21	8/25/21	210819077-01	trans-1,2-Dichloroethylene	156-60-5	EPA-524.2	100	0.5	BDL
8/19/21	8/25/21	210819077-01	Trichloroethylene	79-01-6	EPA-524.2	5	0.5	BDL
8/19/21	8/25/21	210819077-01	Vinyl chloride	75-01-4	EPA-524.2	2	0.5	BDL
8/19/21	8/25/21	210819077-01	Xylenes (total)	1330-20-7	EPA-524.2	10000	0.5	BDL

NT: Not Tested ug/L: Micrograms per Liter MCL: Maximum Contaminant Level BDL Below Laboratory MRL A less than sign (<) may also be used.

210819077-01 Y 1/1
8/30/21