



Tierra Del Sol Industrial Park - 2329 Lava Lane  
 P.O. Box 642, Alamosa, CO 81101  
 Tel: 719-589-1024 Fax: 719-589-3697  
 E - Mail Address: [juliez@sangrelabs.com](mailto:juliez@sangrelabs.com)  
[www.sdclaboratory.com](http://www.sdclaboratory.com)

## Report For Lead And Copper

**System Name:** Navajo Western Water Dist.  
**Mailing Address:** 705 Navajo Rd., Walsenburg, CO 81089  
**Contact Person:** Thom Northup  
**Telephone :** (719) 738-3130  
**E- Mail:** [operator@nwwd.us](mailto:operator@nwwd.us)

**PWSID #:** CO128600  
**County:** Huerfano  
**Water Type:** Community  
**Collected By:** Tom Northup

---

### Laboratory Information

---

**Lab Sample Nos:** 3973-3977  
**Date Received:** 8/19/2020

**Report Date:** 9/2/2020

---

Lab Sample No.:	Sample Location:	Collection Date:	Collection Time:	Lead EPA 200.9 mg/L	Copper SM 3111B mg/L
3973	LCR008 (36 Shawnee)	8/19/2020	7:15 AM	<0.001	<0.005
3974	LCR001 (415 Comanche Dr.)	8/19/2020	4:45 AM	<0.001	0.059
3975	LCR009 (495 Comanche Dr.)	8/19/2020	6:10 AM	<0.001	0.056
3976	LCR002 (5061 Comanche Dr.)	8/19/2020	5:55 AM	<0.001	0.129
3977	LCR005 (968 Chickasaw)	8/19/2020	6:10 AM	<0.001	0.049

**Laboratory's Method Reporting Limit (MRL)**

Copper: 0.005 mg/L  
 Lead: 0.001 mg/L

**MCL (Maximum Contamination Limit)**

Copper: 1.3 mg/L  
 Lead: 0.015 mg/L

< = Less than laboratory's reporting limit  
 mg/L = Milligrams per liter

**Reviewed & Approved by:**  
 Julie Zahringer

**Date:** 9/2/2020

---



Tierra Del Sol Industrial Park - 2329 Lava Lane  
P.O. Box 642, Alamosa, CO 81101  
Tel: 719-589-1024 Fax: 719-589-3697  
E - Mail Address: [juliez@sangrelabs.com](mailto:juliez@sangrelabs.com)  
[www.sdclaboratory.com](http://www.sdclaboratory.com)

## Report For Lead And Copper

**System Name:** Navajo Western Water Dist.  
**Mailing Address:** 705 Navajo Rd., Walsenburg, CO 81089  
**Contact Person:** Thom Northup  
**Telephone :** (719) 738-3130  
**E- Mail:** [operator@nwwd.us](mailto:operator@nwwd.us)

**PWSID #:** CO128625  
**County:** Huerfano  
**Water Type:** Community  
**Collected By:** Tom Northup

---

### Laboratory Information

---

**Lab Sample Nos:** 3978-3982  
**Date Received:** 8/19/2020

**Report Date:** 9/2/2020

Lab Sample No.:	Sample Location:	Collection Date:	Collection Time:	Lead EPA 200.9 mg/L	Copper SM 3111B mg/L
3978	LCR001 (136 Antelope Loop)	8/19/2020	7:00 AM	<0.001	0.031
3979	LCR002 (39 Elk Tr.)	8/19/2020	8:15 AM	<0.001	0.118
3980	LCR003 (119 Buff Dr.)	8/19/2020	5:51 AM	<0.001	0.161
3981	LCR006 (87 Buff Dr.)	8/19/2020	6:10 AM	<0.001	0.255
3982	LCR004 (20 Moose Tr.)	8/19/2020	6:30 AM	<0.001	0.052

**Laboratory's Method Reporting Limit (MRL)**

Copper: 0.005 mg/L  
Lead: 0.001 mg/L

**MCL (Maximum Contamination Limit)**

Copper: 1.3 mg/L  
Lead: 0.015 mg/L

< = Less than laboratory's reporting limit  
mg/L = Milligrams per liter

**Reviewed & Approved by:**  
Julie Zahringer

**Date:** 9/2/2020

---