



Tierra Del Sol Industrial Park - 2329 Lava Lane
P.O. Box 642, Alamosa, CO 81101
Tel: 719-589-1024 Fax: 719-589-3697
E - Mail Address: juliez@sangrelabs.com
www.sdclaboratory.com

Report For Lead And Copper

System Name: Navajo Western Water District Estates
Mailing Address: 705 Navajo Road, Walsenburg, CO 81089
Contact Person: Tom Northup
Phone Number: 719-738-3130
County: Huerfano

PWSID #: CO0128625
Water Type: Community
Collected By: Tom Northup
Email: operator@nwwd.us

Laboratory Information

Lab Sample No's: 4915-4919

Date Received: 8/18/2021

Report Date: 9/7/2021

| Lab Sample Number | Sample Location | LCR | Collection Date | Collection Time | Lead EPA 200.9 mg/L | Copper EPA 200.7 mg/L |
|-------------------|------------------|--------|-----------------|-----------------|---------------------|-----------------------|
| 4915 | 34 ELK TRAIL | LCR002 | 8/18/2021 | 6:27 | < 0.001 | 0.06 |
| 4916 | 119 BUFFALO DR N | LCR003 | 8/18/2021 | Not Specified | < 0.001 | 0.13 |
| 4917 | 20 MOOSE TRAIL | LCR004 | 8/18/2021 | 6:30 | < 0.001 | 0.17 |
| 4918 | 25 BUFFALO DR S | LCR007 | 8/18/2021 | 7:30 | < 0.001 | 0.09 |
| 4919 | 87 BUFFALO DR N | LCR006 | 8/18/2021 | 6:15 | < 0.001 | 0.26 |

Laboratory's Method Reporting Limit (MRL)

Copper: 0.01 mg/L

Lead: 0.001 mg/L

MCL (Maximum Contamination Limit)

Copper: 1.3 mg/L

Lead: 0.015 mg/L

< = Less than laboratory's reporting limit

mg/L = Milligrams per liter

Reviewed & Approved by:

Julie Zahringer

Date: 9/7/2021
