



Tierra Del Sol Industrial Park - 2329 Lava Lane
P.O. Box 642, Alamosa, CO 81101
Tel: 719-589-1024 Fax: 719-589-3697
E - Mail Address: juliez@sangrelabs.com
www.sdclaboratory.com

Nitrate and/or Nitrite Report

Date Collected: 8/19/2020 PWSID #: CO0128600
System Name: Navajo Western Water District
Mailing Address: 705 Navajo Rd., Walsenburg, CO 81089
Time Collected: 8:00 AM County: Huerfano
Contact Person: Tom Northup Water Type: Communtiy
Telephone Number: (719)738-3130 Collected By: Tom Northup
Sample Location: **705 Navajo Rd., Walsenburg, CO @ EP001**
E - Mail: operator@nwwd.us

Laboratory Information

Lab Sample Number: 3983

Date Received: 8/19/2020

Analysis Date: 8/21/2020

Parameter	(mg/L) Result	(mg/L) MCL	(mg/L) MRL	EPA Method
Nitrate - N	4.54	10.0	0.20	300.0

mg/L = Milligrams per liter.

MCL = Maximum Contaminant Level.

MRL = Laboratory's Method Reporting Limit.

Reviewed & Approved by:

Julie Zahringer

Date: 8/25/2020



Tierra Del Sol Industrial Park - 2329 Lava Lane
P.O. Box 642, Alamosa, CO 81101
Tel: 719-589-1024 Fax: 719-589-3697
E - Mail Address: juliez@sangrelabs.com
www.sdclaboratory.com

Nitrate and/or Nitrite Report

Date Collected: 8/19/2020 PWSID #: CO0128625
System Name: Navajo Western Water District
Mailing Address: 705 Navajo Rd., Walsenburg, CO 81089
Time Collected: 9:51 AM County: Huerfano
Contact Person: Tom Northup Water Type: Communtiy
Telephone Number: (719)738-3130 Collected By: Tom Northup
Sample Location: **705 Navajo Rd., Walsenburg, CO @ EP003**
E - Mail: operator@nwwd.us

Laboratory Information

Lab Sample Number: 3986

Date Received: 8/19/2020

Analysis Date: 8/21/2020

Parameter	(mg/L) Result	(mg/L) MCL	(mg/L) MRL	EPA Method
Nitrate - N	2.97	10.0	0.20	300.0

mg/L = Milligrams per liter.

MCL = Maximum Contaminant Level.

MRL = Laboratory's Method Reporting Limit.

Reviewed & Approved by:

Julie Zahringer

Date: 8/25/2020
