



Tierra Del Sol Industrial Park - 2329 Lava Lane
P.O. Box 642, Alamosa, CO 81101
Tel: 719-589-1024 Fax: 719-589-3697
E - Mail Address: juliez@sangrelabs.com
www.sdclaboratory.com

Nitrate-N Report

Date Collected: 8/18/2021 **PWSID #:** CO0128600
System Name: Navajo Western Water District Resorts
Mailing Address: 705 Navajo Rd., Walsenburg, CO 81089
Time Collected: 8:00 AM **County:** Huerfano
Contact Person: Tom Northup **Water Type:** Community
Telephone Number: (719) 738-3138 **Collected By:** Tom Northup
Sample Location: 705 Navajo Rd. @ Entry Point 001

E - Mail: operator@nwwd.us

Laboratory Information

Lab Sample Number: 4920

Date Received: 8/18/2021

Analysis Date: 8/18/2021

Parameter	(mg/L) Result	(mg/L) MCL	(mg/L) MRL	EPA Method
Nitrate - N	4.11	10.0	0.20	300.0

mg/L = Milligrams per liter.

MCL = Maximum Contaminant Level.

MRL = Laboratory's Method Reporting Limit.

Reviewed & Approved by:

L. Shriber de Cuevas

Date: 8/20/2021



Tierra Del Sol Industrial Park - 2329 Lava Lane
P.O. Box 642, Alamosa, CO 81101
Tel: 719-589-1024 Fax: 719-589-3697
E - Mail Address: juliez@sangrelabs.com
www.sdclaboratory.com

Nitrate-N Report

Date Collected: 8/18/2021 **PWSID #:** CO0128625
System Name: Navajo Western Water District Estates
Mailing Address: 705 Navajo Rd., Walsenburg, CO 81089
Time Collected: 9:20 AM **County:** Huerfano
Contact Person: Tom Northup **Water Type:** Community
Telephone Number: (719) 738-3130 **Collected By:** Tom Northup
Sample Location: 176 Badger Rd. @ Entry Point 003

E - Mail: operator@nwwd.us

Laboratory Information

Lab Sample Number: 4924

Date Received: 8/18/2021

Analysis Date: 8/18/2021

Parameter	(mg/L) Result	(mg/L) MCL	(mg/L) MRL	EPA Method
Nitrate - N	2.86	10.0	0.20	300.0

mg/L = Milligrams per liter.

MCL = Maximum Contaminant Level.

MRL = Laboratory's Method Reporting Limit.

Reviewed & Approved by:

L. Shriber de Cuevas

Date: 8/20/2021
