



Tierra Del Sol Industrial Park - 2329 Lava Lane
P.O. Box 642, Alamosa, CO 81101
Tel: 719-589-1024 Fax: 719-589-3697
E - Mail Address: juliez@sangrelabs.com
www.sdclaboratory.com

Fluoride, Nitrate, Nitrite Report

System Name: Navajo Western Water District Estates
PWSID #: CO0128625
Sample Location: 176 Badger Rd. @ Entry Point
Facility ID: 003
Sample Point ID: 003
Date Collected: 8/17/2022
Time Collected: 9:30 AM
Collected By: Tom Northup
Contact Person: Tom Northup
Telephone Number: (719) 738-3138
Email: operator@nwwd.us

Laboratory Information

Lab Sample Number: 5780

Date Received: 8/17/2022

Analysis Date: 8/17/2022

Parameter	(mg/L) Result	(mg/L) MCL	(mg/L) MRL	EPA Method
Fluoride	0.64	4.0	0.20	300.0
Nitrate - N	2.41	10.0	0.20	300.0
Nitrite - N	< 0.20	1.0	0.20	300.0

mg/L = Milligrams per liter.

MCL = Maximum Contaminant Level.

MRL = Laboratory's Method Reporting Limit.

Reviewed & Approved by:

L. Shriber de Cuevas

Date: 8/19/2022
