



Tierra Del Sol Industrial Park - 2329 Lava Lane
P.O. Box 642, Alamosa, CO 81101
Tel: 719-589-1024 Fax: 719-589-3697
E - Mail Address: juliez@sangrelabs.com
www.sdclaboratory.com

System Name: Navajo Western Water District Resorts
PWSID #: CO0128600
Sample Location: 705 Navajo Rd. @ Entry Point
Facility ID: 001
Sample Point ID: 001
Date Collected: 8/8/2023
Time Collected: 7:45 AM
Collected By: Tom Northup
Contact Person: Tom Northup
Telephone Number: (719) 738-3138
Email: operator@nwwd.us

Laboratory Information

Lab Sample Number: 6402

Date Received: 8/8/2023

Analysis Date: 8/8/2023

Parameter	(mg/L) Result	(mg/L) MCL	(mg/L) MRL	EPA Method
Nitrate - N	3.25	10.0	0.20	300.0

mg/L = Milligrams per liter.

MCL = Maximum Contaminant Level.

MRL = Laboratory's Method Reporting Limit.

Reviewed & Approved by:

L. Shriber de Cuevas

Date: 8/10/2023
