

NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

OPERATIONS REPORT FOR DECEMBER 2020

Water Pumped: Resorts, 766,352 gals., Estates, 157,441 = 923,793 gallons. Through 11/30/2020

Usage by Customers: 608,208 gallons

Items Purchased:

Work Accomplished:

1. Passed the monthly coliform tests.
2. Assist customers with leaks.
3. Snow removal.
4. Royal Electric installed new Cl2 pump at the Estates, and repaired Well#6 lightning damage.
5. Replace well meter gasket and Cl2 valve at Estates.
6. Replace Meter Yolk at 143 Antelope Loop, live!
7. Install new tap at 146 Antelope Loop..
8. Generator estimates.
9. USA Bluebook- Correlator- Data Loggers?

Request – Tool Box - Fuel

Date: 12/14/2020

Tech: Tom Northup