

NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

OPERATIONS REPORT FOR APRIL 2020

Water Pumped: Resorts, 770,487 gals., Estates, 228,952. = 999,439 gallons. Through 3/30/2020

Usage by Customers: 594,117 gallons

Items Purchased: Gateway and Generator for the Estates. Meters pit and assembly.

Work Accomplished:

1. Passed the monthly coliform tests.
2. Prep for and repair leak at Estates Tank site. Faulty coupling - installed in 2012.
3. Install Tap at F-4, Lot-137.
4. Generator and Propane Tank installed and online at Estates.
5. Webinar provided by CRWA for mandatory Training Units.
6. Leak Survey.
7. Set up new control panel at Estates Tank Site.
8. Locate Main's for County, new culverts.
9. Sign and send proposal acceptance to Great Plains Structures for Tank Inspection and Maint.
- 10.

Request –

Date: 04/013/20

Tech: Tom Northup