

NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

OPERATIONS REPORT FOR AUGUST 2020

Water Pumped: Resorts,930,335 gals., Estates , 205,510 = 1,135,845 gallons. Through 08/28/20

Usage by Customers: 785,739 gallons

Items Purchased: System repair parts, battery backup supplies for Site #2-B.

Work Accomplished:

1. Passed the monthly coliform tests.
2. Mow Sites and office.
3. Met with Guy Pence and Rog Gravatt, Great Plains Structures.
4. Compact and close brush pit.
5. Troubleshoot and repair/replace SSR's at well sites on, 7/19- 7/26 and 7/31. Install DLP in main panel.
6. Royal electric here on 7/27. Diagnose and temp bypass on controls.
7. Correspond with CDHPE concerning DI(2) Estates.
- 8.
- 9.
- 10.

Request –

Date: 08/10/20
Tech: Tom Northup