

NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

OPERATIONS REPORT FOR OCTOBER 2021

Water Pumped: Resorts, 702,825., Estates, 181,753 = 884,578 gallons. Through 09/30/21

Usage by Customers: 808,372 gallons Loss= 75,936 = 8.5%

Items Purchased: .

Work Accomplished:

1. Passed the monthly coliform tests.
2. Install Tap F- 5, Lot-73
3. Deliver LCR results to customers, submit all related paperwork to the Portal .
4. Received VOC/SOC, TTHM, HAA5 results. Everything looks great.
5. Compile and send new website info to AshcaTek.
6. Shop Generator due in November.
7. Pour concrete pad for shop generator.
8. Assist customers with leaks.
9. Static well levels.

Date 10/11/2021

Request ____