

NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

OPERATIONS REPORT FOR NOVEMBER 2021

Water Pumped: Resorts, 622,194 Estates, 167,450 = 789,644 gallons. Through 10/27/21

Usage by Customers: 690,809 gallons Loss= 98,835 = 9.5%

Items Purchased: Laptop -for VGB \$540.67

Work Accomplished:

1. Passed the monthly coliform tests.
2. Di2 Lab results for Estates received and posted.
3. Website on-line.
4. Deploy Leak Correlator.
5. Vacation.
6. Troubleshoot issues with Meter Reading System.
7. Shop generator arrived, scheduling install.
8. Assist customers with leaks.

Date 11/10/2021

Request ____