

NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

OPERATIONS REPORT FOR DECEMBER 2021

Water Pumped: Resorts, 596,282 Estates, 167,201 = 763,483 gallons. Through 11/26/21

Usage by Customers: 677,833 gallons Loss= 85,560 = 11.2% , 1.9 GPM

Items Purchased:

Work Accomplished:

1. Passed the monthly coliform tests.
2. Pour pad for Shop/Office Generator. Generator and Propane supply installed and online.
3. AshcaTek updated meter reading laptop.
4. Locate valves and lines for County.
5. County stockpiled gravel.
6. Assist customers with leaks.
7. Met with Adam Battaia, Pinon Hills.
8. Tank Site's #2-B and #3 now have redundant communication.

Date 12/18/2021

Request Well Generator