

# NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

## OPERATIONS REPORT FOR JUNE 2021

Water Pumped: Resorts, 802,831 gals., Estates, 120,132 = 923,063 gallons. Through 05/31/21

Usage by Customers: 667,342 gallons

---

Items Purchased:

---

Work Accomplished:

1. Passed the monthly coliform tests.
2. Install Tap, F-3 , Lot 62.
3. LaVeta Propane, installed tanks and lines at Well #6 and Site #2
4. Replace Relays on all Wells.
5. Install grounding/lightning protection on Well,s #6-8-3-1-7
6. Install test ports on four wells.
7. Site #2, Royal Electric troubleshoot and repair power supply.
8. Royal Electric replaced chlorinator at Main Site
9. Mow Office site.

Date. 06/14/2021

Request\_\_\_\_

