

# NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

## OPERATIONS REPORT FOR JULY 2021

Water Pumped: Resorts, 1,172,081., Estates, 209,421 = 1,381,502 gallons. Through 06/30/21

Usage by Customers: 934,953 gallons Loss-24.4%

---

Items Purchased:

---

Work Accomplished:

1. Passed the monthly coliform tests.
2. Install Tap 5-133
3. Well Meter Certification.
4. Published CCR.
5. Web-site issues!
6. New Accounting Form site ,State.
7. Repair Leak ,Navajo Rd.
8. Weed-eat Estates Sites.
9. Mow Office site.

Date. 07/12/2021

Request\_\_\_\_