

NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

OPERATIONS REPORT FOR SEPTEMBER 2021

Water Pumped: Resorts, 749,516., Estates, 187,689 = 937,205 gallons. Through 08/31/21

Usage by Customers: 881,372 gallons Loss= 55,833 , 5.9%

Items Purchased: Leak correlator.

Work Accomplished:

1. Passed the monthly coliform tests.
2. Install Tap F- 4, Lot-10
3. Collect and deliver 2021 LCR, Voc's, Nitrate and Di2 samples to the Lab .
4. Bring Site#2 Tank Level monitor back on-line
5. Nitrates, Estates-2.86Mg/L and Resorts-4.11Mg/L .
6. Lead and Copper result's, looks great.
7. Coronavirus State and Local Fiscal Recovery Funds?

Date. 09/13/2021

Request____