

NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

OPERATIONS REPORT FOR January 2022

Water Pumped: Resorts, 733,931 Estates, 181,645 = 915,576 gallons. Through 12/31/2021

Usage by Customers: 868,651 gallons Loss= 46,925 = 5.1%, 1.3 GPM

Items Purchased:

Work Accomplished:

1. Passed the monthly coliform tests
2. Install 12v backup supplies at Site #2-B and Site #3.
3. Contact Samsara about control issues. Contact Royal Electrical for assistance.
4. Locate major customer leaks.
5. Well 1 Generator Quote. \$9757.51
6. Assist customers with leaks.
7. Deployed Z-Corr, checking customer service line for leak location.
8. Submit 2021 HCFMLD Grant Application.
9. San Isabel Electric disconnected old service from the office.

01/02/2022

Request