

NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

OPERATIONS REPORT FOR October 2022

Water Pumped: Resorts, 663,882 Estates, 169,610 = 833,492 gallons. Through 09/31/2022

Usage by Customers: 781,431 Loss= 6%

Items Purchased:

Work Accomplished:

1. Passed the monthly coliform tests
2. Install 2 taps, Filing 3- Lot 114 and 3-145
4. Well #8 and meter, back online.
6. Mow and weed-eat office, shop, and tank sites.
7. Install throttling valve, well#1 estates.
8. Rehab well #1 Estates, online at 25 GPM.
9. Main Site Gateway unit issues.
10. Assist Customers with leaks.

10/12/2022

Vacation