

# NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

## OPERATIONS REPORT FOR DECEMBER2022

Water Pumped: Resorts, 563,696 Estates, 131,099 = 694,705 gallons. Through 11/30/2022

Usage by Customers: 638,059 Loss= 9%

---

Items Purchased:

---

Work Accomplished:

1. Passed the monthly coliform tests
2. Standby generator installed at Well Site 1.
3. Checked manual start and run on all generators.
4. Installed egress handles on well meter pits.
5. Completed inventory.
6. Submit grant to HCFMLD for Well #7 standby generator. Received \$5400. Total cost \$13,456.16, District cost 8056.16.
7. Assist Customers with leaks.
8. Field Logic unit updated, Sensus.
10. TTHM and HAA5 testing requirements reduced from annually to every 3 years. \$450/year.
11. Received new meters from WinnWater.

12/14/2022