

# NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

## OPERATIONS REPORT FOR May 2022

Water Pumped: Resorts, 548,647 Estates, 165,179 = 713,826 gallons. Through 04/30/2022

Usage by Customers: 644,320 gallons Loss= 69,506 = 9%

---

Items Purchased:

---

Work Accomplished:

1. Passed the monthly coliform tests
2. Install generator pad at Well#1
4. Assist customers with leaks.
5. Install Tap Filing 3- Lot 70 and Filing 2- Lot 100
6. Service equipment.
7. Weed-eat Estates well site.
8. Install handles, well #1- and #5-meter pit's.
9. Install Tap at Filing 2 – Lot 159
10. Troubleshoot Well #3 (power surge).

05/11/2022

Request