

NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

OPERATIONS REPORT FOR JUNE 2022

Water Pumped: Resorts, 604,142 Estates, 169,929 = 774071 gallons. Through 05/31/2022

Usage by Customers: 710,413 gallons Loss= 63,658 = 8.2%

Items Purchased: 6 – Led Shop Lights - \$69.98

Work Accomplished:

1. Passed the monthly coliform tests
2. Replace GFI at Well #3 and remove 3-way switches in the shop.
4. Install new led lighting in the shop.
6. Mow and weed-eat Site#2, Office and Estates Tank site.
7. Repair leak at 620 Cochise. 2 hrs.
8. Backfill previous taps.
9. Install Tap at Filing 3- Lot 87
10. Install Tap, filing 1- Lot 11
11. Attended Mandatory Regulatory training class in Alamosa.
12. Assist customers with Leaks
13. Ken installed router at Site #2
14. Ordered Meters, MXU's , setter's and pit assembly's.

06/08/2022

Request 2 vacation days- 1-2 of August.