

NAVAJO WESTERN WATER DISTRICT TECHNICIAN REPORT

OPERATIONS REPORT FOR AUGUST 2022

Water Pumped: Resorts, 702,022 Estates, 173,418 = 875,440 gallons. Through 07/31/2022

Usage by Customers: 801,324 gallons Loss= 62,530 = 7.1%

Items Purchased: Tools- \$68.65, Repair Fittings \$113.88

Work Accomplished:

1. Passed the monthly coliform tests
2. Backfill Taps.
4. Repair leak in shop and replace meter.
6. Mow and weed-eat office, shop, and tank sites.
7. Replace Pump at Well#7, Ojo Drilling.
8. Replace Check Valve in Well#2, Estates
9. Estates Well #1 drawing air, shut down. Test Draw down and Recovery. 13.5 ft draw down and 4.5 min recovery. Contact Cotey Well Service.
10. Assist Customers with leaks.
11. Generator for Well#1-A.
12. Trouble shoot mower.
13. Leak, Cheyenne Pl.