



NAVAJO WESTERN WATER DISTRICT
705 Navajo Road; Walsenburg, CO 81089
Telephone: 719-738-3130 / Email: operator@nwwd.us

NAVAJO WESTERN WATER DISTRICT
OPERATIONS REPORT FOR August 2024

Water Pumped: Resorts, 729,559 Estates, 163,601 = 893,160 gallons.
Through 08/31/2024

Usage by Customers: 738,081 = Loss of (155,079) 17.3% Loss

JKL: (30,000) Tanks: (55,000) 971. Navajo Rd. (30,000) Estates Flush (15,000)

Actual Loss: 25,079 Gallons

Work Accomplished:

- 1. Passed Monthly Coliform Test.**
- 2. Fiber Locates.**
- 3. Comp Tank Inspections.**
- 4. 971 Navajo Rd. service line leak repaired.**
- 5. Hypo chlorinator Injectors Serviced Resorts/Estates**
- 6. Kyra WQCD meeting, updated and submitted monitoring plan/Schematics.**
- 7. Tank 2C repair/ 3C new bulkhead.**
- 8. Assisted customers with Leaks. (120 Buffalo Dr. north, 189 Mohawk Cir.)**
- 9. Customer complaints.**
- 10. Tap Install Filing #5 lot #113. |**
- 11. Augmentation report submitted to State.**
- 12. Booster site #2 New motor starter relay, arrestor and selector relay.**
- 13. Lead and copper samples collected and delivered, Waiting for test results**

Requests: Water Overage Articles.

Thank You All!

Dave Rabideau ORC