



NAVAJO WESTERN WATER DISTRICT
705 Navajo Road; Walsenburg, CO 81089
Telephone: 719-738-3130 / Email: operator@nwwd.us

**NAVAJO WESTERN WATER DISTRICT
OPERATIONS REPORT FOR JULY 2026**

**Water Pumped: Resorts, 623,823 Estates, 170,082 = 793,905 gallons Through,
07/31/2026**

Usage by Customers: 742,785 = Loss 51,120 (6.4%)

Work Accomplished:

- 1. Second Check Valve replaced at Resorts treatment plant, last one in route.**
- 2. Estates Well #1 Raw water line Repaired.**
- 3. TTHM & HAA5s Collected and submitted last tests for this water year.**
- 4. Well #5 new meter register and measuring Barrel, Calibrated.**
- 5. Estates solution barrel evacuated cleaned.**
- 6. Estates discharge drain/ CL2 Feed clogged, causing pump to gas, New CL2 pump Calibrated.**
- 7. Resorts and Estates CL2 ejectors replaced.**
- 8. Courtesy Meter Reads**
- 9. Assisted customers with Leaks. (1213 Chickasaw, 100 Kiowa Pl, 1846 Cherokee Dr, 3009 Comanche Dr, 54 Cheyenne Pl, 3027 Comanche Dr, 131 Navajo Rd, 3211 CR510, 22 Choctaw Dr, 1202 Chickasaw Dr.)**
- 10. Well #1 new raw water flow valve.**
- 11. Updated finished storage water inspection plans.**
- 12. Augmentation report submitted to State.**
- 13. Tank Site yard work, overflows cleared.**
- 14. Comanche main repair and Dirt work.**
- 15. Truck to OI reliable, due for recall, August 25th.**
- 16. Locates 3681 CR510, 4079 Comanche Dr.**
- 17. Updated Monitoring Schedules/ Resident Drought letter.**

Requests: 1202 Chickasaw Dr, 671 Ute Dr, 1213 Chickasaw Dr.

Thank You All! Dave Rabideau ORC