



NAVAJO WESTERN WATER DISTRICT
705 Navajo Road; Walsenburg, CO 81089
Telephone: 719-738-3130 / Email: operator@nwwd.us

NAVAJO WESTERN WATER DISTRICT
OPERATIONS REPORT FOR August 2026

Water Pumped: Resorts, 620,169 Estates, 156,175 = 776,344 gallons Through, 08/31/2026

Usage by Customers: 714,052 = Loss 62,292 (8.2%)

Comanche Leak 11,000-12,000 Gallons

Work Accomplished:

- 1. Bac-T Samples submitted.**
- 2. Resorts Pump last silent check valve replaced.**
- 3. Resorts pump 1A overload, replacement maybe under warranty.**
- 4. Truck recall, Fixed. Transmission downshifting without warning.**
- 5. Estates solution barrel evacuated cleaned.**
- 6. WFDSS final reports from Jackson CRWA.**
- 7. Resorts and Estates CL2 ejectors Cleaned.**
- 8. Courtesy Meter Reads x3**
- 9. Leak investigations. (3089 Comanche, 620 Cochise, 32 Choctaw Dr, 26 Seneca, 282 Seneca Cir, 4131 CR510, 3027 Comanche Dr,)**
- 10. Draw down recovery tests x2**
- 11. Polly Tank periodic inspection reports.**
- 12. Augmentation report submitted to State.**
- 13. Locates (867 Navajo Rd., 44 Choctaw Dr.)**
- 14. Resorts potential backflow issue, Possible bad seal in pump under motor.**
- 15. Air in the resorts system, all wells checked individually.**
- 16. Sensus Support, MXUs and supporting Components replaced.**

Requests: 4131 Comanche Dr, 1213 Chickasaw Dr, 671 Ute, 22 Choctaw Dr

Thank You All! Dave Rabideau ORC